



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Name of Sampler: Lisa Christensen
Date Collected: 10/18/2018
School Name: Tukwila Elementary
School Code: 3488
School District Name: Tukwila
Address: 5939 S 149th St, Tukwila WA 98168
County: King
Number of Samples Collected: 63
School Point of Contact: Liliana Cardenas
Title of POC: Director of Maintenance and Operations
Email of POC: CardenasL@tukwila.wednet.edu
POC Phone Number: (206) 901-8020
Date sent to State Lab: 10/18/2018
Date Received by Lab:
Shipment Tracking Number: 804933028544, 813380573544

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	15089	First Draw	Tap	Kitchen	1	11/01/2018	Food Prep Sink, 6:05 AM
2.	15090	First Draw	Bubbler	Outside Gym	TB	11/01/2018	Left Side Fountain
3.	15091	First Draw	Bubbler	Outside Gym	<1	11/01/2018	Right Side Fountain
4.	15092	First Draw	Tap	Nurse's Office	1	11/01/2018	
5.	15093	First Draw	Bubbler	Room B116	<1	11/01/2018	
6.	15094	First Draw	Tap	Room B116	1	11/01/2018	
7.	15095	First Draw	Bubbler	Room B119	<1	11/01/2018	
8.	15096	First Draw	Tap	Room B119	1	11/01/2018	
9.	15097	First Draw	Bubbler	Room C101	<1	11/01/2018	
10.	15098	First Draw	Tap	Room C101	1	11/01/2018	
11.	15099	First Draw	Bubbler	Room C102	<1	11/01/2018	
12.	15100	First Draw	Tap	Room C102	TB	11/01/2018	
13.	15101	First Draw	Bubbler	Room C103	3	11/01/2018	
14.	15102	First Draw	Tap	Room C103	3	11/01/2018	
15.	15103	First Draw	Bubbler	Room C104	<1	11/01/2018	
16.	15104	First Draw	Tap	Room C104	<1	11/01/2018	
17.	15105	First Draw	Bubbler	Room D100	2	11/01/2018	
18.	15106	First Draw	Tap	Room D100	1	11/01/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	15107	First Draw	Bubbler	Room D101	<1	11/01/2018	
20.	15108	First Draw	Tap	Room D101	<1	11/01/2018	
21.	15109	First Draw	Bubbler	Room D108	1	11/01/2018	
22.	15110	First Draw	Tap	Room D108	1	11/01/2018	No Aerator
23.	15111	First Draw	Bubbler	Room D109	<1	11/01/2018	
24.	15112	First Draw	Tap	Room D109	1	11/01/2018	
25.	15113	First Draw	Bubbler	Room C108	<1	11/01/2018	
26.	15114	First Draw	Tap	Room C108	4	11/01/2018	
27.	15115	First Draw	Bubbler	Room C111	<1	11/01/2018	
28.	15116	First Draw	Tap	Room C111	1	11/01/2018	
29.	15117	First Draw	Bubbler	Room C112	TB	11/01/2018	
30.	15118	First Draw	Tap	Room C112	TB	11/01/2018	
31.	15119	First Draw	Bubbler	Room C116	<1	11/01/2018	
32.	15120	First Draw	Tap	Room C116	1	11/01/2018	
33.	15121	First Draw	Bubbler	Room B120	<1	11/01/2018	
34.	15122	First Draw	Tap	Room B120	1	11/01/2018	
35.	15123	First Draw	Bubbler	Near 2nd Floor Elevator	1	11/01/2018	Left Side
36.	15124	First Draw	Bubbler	Near 2nd Floor Elevator	<1	11/01/2018	Right Side

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
37.	15125	First Draw	Bubbler	Room B213	<1	11/01/2018	
38.	15126	First Draw	Tap	Room B213	1	11/01/2018	
39.	15127	First Draw	Tap	Room B206	1	11/01/2018	Left Side Sink
40.	15128	First Draw	Tap	Room B206	4	11/01/2018	Right Side Sink
41.	15129	First Draw	Bubbler	Room B210	<1	11/01/2018	
42.	15130	First Draw	Tap	Room B210	1	11/01/2018	
43.	15131	First Draw	Bubbler	Room C215	<1	11/01/2018	
44.	15132	First Draw	Tap	Room C215	<1	11/01/2018	
45.	15133	First Draw	Bubbler	Room C211	<1	11/01/2018	
46.	15134	First Draw	Tap	Room C211	1	11/01/2018	
47.	15135	First Draw	Bubbler	Room C210	<1	11/01/2018	
48.	15136	First Draw	Tap	Room C210	<1	11/01/2018	
49.	15137	First Draw	Bubbler	Room C107	<1	11/01/2018	
50.	15138	First Draw	Tap	Room C107	1	11/01/2018	
51.	15139	First Draw	Bubbler	Room C204	<1	11/01/2018	
52.	15140	First Draw	Tap	Room C204	<1	11/01/2018	Hot tap used by staff member
53.	15141	First Draw	Bubbler	Room C203	2	11/01/2018	
54.	15142	First Draw	Tap	Room C203	3	11/01/2018	No Aerator

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
55.	15143	First Draw	Bubbler	Room C202	2	11/01/2018	
56.	15144	First Draw	Tap , Blank	Room C202	2	11/01/2018	
57.	15145	First Draw	Bubbler	Room C201	2	11/01/2018	
58.	15146	First Draw	Tap	Room C201	2	11/01/2018	
59.	15147	First Draw	Bubbler	Room B208	TB	11/01/2018	
60.	15148	First Draw	Tap	Room B208	TB	11/01/2018	
61.	15149	First Draw	Bubbler	Room B205	2	11/01/2018	
62.	15150	First Draw	Tap	Room B205	TB	11/01/2018	
63.	15151	Blank	Blank		1	11/01/2018	03453, in Music Room