



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Tidewater

Project Name: Middletown High

Meneka Rodrigo
6625 Selnick Drive, Suite A
Elkridge, MD 21075

Project / PO Number: N/A
Received: 11/15/2018
Reported: 11/30/2018

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (W01A-13 3033 (DF), Drinking Water, 18K0841-01, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (5.7), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (11/27/18 1324), Analyzed (11/27/18 1750), Analyst (LMH)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (W01A-11 3033 (DF), Drinking Water, 18K0841-02, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (16.7), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (11/27/18 1324), Analyzed (11/27/18 1751), Analyst (LMH)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (W01A-17 3033 (DF), Drinking Water, 18K0841-03, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (18.1), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (11/27/18 1324), Analyzed (11/27/18 1752), Analyst (LMH)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (W01A-06 3033 (DF), Drinking Water, 18K0841-04, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (8.5), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (11/27/18 1324), Analyzed (11/27/18 1753), Analyst (LMH)



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: W01A-04 3033 (DF) D/B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:17
Lab Sample ID: 18K0841-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1754	LMH

Client Sample ID: W01A-07 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:45
Lab Sample ID: 18K0841-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.9	20.0	1.0	ppb		11/27/18 1324	11/27/18 1755	LMH

Client Sample ID: W01A-15 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:52
Lab Sample ID: 18K0841-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1757	LMH

Client Sample ID: W01A-18 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:54
Lab Sample ID: 18K0841-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1801	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: W01A- 16 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 5:06
Lab Sample ID: 18K0841-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1802	LMH

Client Sample ID: W01A-03 3033 (DF) D/B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:37
Lab Sample ID: 18K0841-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1803	LMH

Client Sample ID: K17-03 3033 (IM)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 5:03
Lab Sample ID: 18K0841-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1806	LMH

Client Sample ID: K17-02 3033 (IM)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:50
Lab Sample ID: 18K0841-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1807	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: W01A-19 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:47
Lab Sample ID: 18K0841-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		11/27/18 1324	11/27/18 1808	LMH

Client Sample ID: W01A-14 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:20
Lab Sample ID: 18K0841-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1809	LMH

Client Sample ID: W01A-12 3033 (DF) Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:11
Lab Sample ID: 18K0841-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1810	LMH

Client Sample ID: W01A-12 3033 (DF) Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:11
Lab Sample ID: 18K0841-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1814	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: K17-06 3033 (IM)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:30
Lab Sample ID: 18K0841-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.6	20.0	1.0	ppb		11/27/18 1324	11/27/18 1815	LMH

Client Sample ID: S23-001 3033 (NO)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:32
Lab Sample ID: 18K0841-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.4	20.0	1.0	ppb		11/27/18 1324	11/27/18 1816	LMH

Client Sample ID: K17-01 3033 (IM)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:28
Lab Sample ID: 18K0841-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1817	LMH

Client Sample ID: K31-03 3033 (KS) Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:21
Lab Sample ID: 18K0841-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.5	20.0	1.0	ppb		11/27/18 1324	11/27/18 1820	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: K31-03 3033 (KS) Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:22
Lab Sample ID: 18K0841-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	6.7	20.0	1.0	ppb		11/27/18 1324	11/27/18 1824	LMH

Client Sample ID: K31-02 3033 (KS)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:34
Lab Sample ID: 18K0841-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.9	20.0	1.0	ppb		11/27/18 1324	11/27/18 1828	LMH

Client Sample ID: K31-01 3033 (KS) Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:36
Lab Sample ID: 18K0841-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	17.5	20.0	1.0	ppb		11/27/18 1324	11/27/18 1829	LMH

Client Sample ID: K31-01 3033 (KS) Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:37
Lab Sample ID: 18K0841-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	29.5	20.0	1.0	ppb		11/27/18 1324	11/27/18 1830	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: W01A-09 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:57
Lab Sample ID: 18K0841-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1831	LMH

Client Sample ID: W01A-02 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:35
Lab Sample ID: 18K0841-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		11/27/18 1324	11/27/18 1832	LMH

Client Sample ID: S23-031 3033 (OT)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:08
Lab Sample ID: 18K0841-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.4	20.0	1.0	ppb		11/27/18 1324	11/27/18 1833	LMH

Client Sample ID: W01B-01 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:59
Lab Sample ID: 18K0841-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	11.3	20.0	1.0	ppb		11/27/18 1324	11/27/18 1834	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: W01B-02 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:57
Lab Sample ID: 18K0841-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	11.3	20.0	1.0	ppb		11/27/18 1324	11/27/18 1835	LMH

Client Sample ID: S23-201 3033 (TL)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:41
Lab Sample ID: 18K0841-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1836	LMH

Client Sample ID: W01A-10 3033 (DF)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:53
Lab Sample ID: 18K0841-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	16.5	20.0	1.0	ppb		11/27/18 1324	11/27/18 1842	LMH

Client Sample ID: S23-195 3033 (HE)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:51
Lab Sample ID: 18K0841-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		11/27/18 1324	11/27/18 1843	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: S23-202 3033 (HE)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 3:49
Lab Sample ID: 18K0841-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.9	20.0	1.0	ppb		11/27/18 1324	11/27/18 1845	LMH

Client Sample ID: S23-190 3033 (HE)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:00
Lab Sample ID: 18K0841-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	6.9	20.0	1.0	ppb		11/27/18 1324	11/27/18 1846	LMH

Client Sample ID: K17-04 3033 (IM)	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:22
Lab Sample ID: 18K0841-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1324	11/27/18 1847	LMH

Client Sample ID: S23-207 3033 (OT) Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:44
Lab Sample ID: 18K0841-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	44.4	20.0	1.0	ppb		11/27/18 1324	11/27/18 1848	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Client Sample ID: S23-207 3033 (OT) Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:45
Lab Sample ID: 18K0841-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	21.8	20.0	1.0	ppb		11/27/18 1329	11/28/18 1650	LMH

Client Sample ID: W01A-03 3033 (DF) B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:37
Lab Sample ID: 18K0841-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		11/27/18 1329	11/28/18 1653	LMH

Client Sample ID: W01A-043033 (DF) D	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 11/15/2018 4:17
Lab Sample ID: 18K0841-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/27/18 1329	11/28/18 1653	LMH

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact	Yes	Containers Intact	Yes
Received on ice or not required.	Yes	Radiation Scan Acceptable or not required.	Yes
COC Present	Yes	COC/Containers Agree	Yes
Correct Preservation	No	Correct Number of Containers Received	Yes
Sufficient Sample Volume	Yes	Proper Condition	Yes

Project Requested Certification(s)

Microbac Laboratories, Inc. - Baltimore
109

State of Maryland (Drinking Water)



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18K0841

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "Jake Mason", is written over a light gray rectangular background.

Jake Mason

Client Relations

Reported: 11/30/2018 16:07

Microbac Laboratories, Inc.

2101 Van Deman Street | Baltimore, MD 21224 | 410.633.1800 p | www.microbac.com

Page 11 of 13



10K0841

18K0841



Multiple Sample COC

Site: **Middletown High: 200 Schoolhouse Drive, Office Ph.: Middletown, MD 21769**

Date Sampled: **Thursday November 15, 2018**

Row	Area Number/Room/Space	From Item Description	Sample Name:	Date/Time Sampled (ex: 03/01/2018 13:28)	Sampler's Name
✓	1 Across RM 309	Drinking Fountain, Refrigerated	✓ W01A-13 3033 (DF)	Thursday November 15, 2018 3:09	Dhanushka Gamage
✓	2 AG Shop RM 440	Drinking Fountain, Refrigerated	✓ W01A-11 3033 (DF)	Thursday November 15, 2018 4:02	Dhanushka Gamage
✓	3 Boys Locker RM	Drinking Fountain, Refrigerated	✓ W01A-17 3033 (DF)	Thursday November 15, 2018 5:01	Dhanushka Gamage
✗	4 Cafe Kitchen End	Drinking Fountain, Refrigerated	W01A-05 3033 (DF) REMOVED	Thursday November 15, 2018	Dhanushka Gamage
✓	5 Cafe Kitchen End	Drinking Fountain, Refrigerated	✓ W01A-06 3033 (DF)	Thursday November 15, 2018 3:15	Dhanushka Gamage
✓	6 Cafe West End @ RM 119	Drinking Fountain, Refrigerated	✓ W01A-04 3033 (DF) D/B	Thursday November 15, 2018 4:17	Dhanushka Gamage
✓	7 Cust Hall @ RM 421	Drinking Fountain, Refrigerated	✓ W01A-07 3033 (DF)	Thursday November 15, 2018 3:45	Dhanushka Gamage
✓	8 Girls Locker RM	Drinking Fountain, Refrigerated	✓ W01A-15 3033 (DF)	Thursday November 15, 2018 4:52	Dhanushka Gamage
✓	9 Gym Floor Lower End	Drinking Fountain, Refrigerated	✓ W01A-18 3033 (DF)	Thursday November 15, 2018 4:59	Dhanushka Gamage
✓	10 Gym Floor School Side	Drinking Fountain, Refrigerated	✓ W01A-163033 (DF)	Thursday November 15, 2018 5:06	Dhanushka Gamage
✓	11 GYM MEZZ @ Conc. Stand	Drinking Fountain, Refrigerated	✓ W01A-03 3033 (DF) D/B	Thursday November 15, 2018 4:37	Dhanushka Gamage
✓	12 Gym Storage Room	Ice Machine	✓ K17-03 3033 (IM)	Thursday November 15, 2018 5:03	Dhanushka Gamage
✓	13 Gym Trainer Room	Ice Machine	✓ K17-02 3033 (IM)	Thursday November 15, 2018 4:50	Dhanushka Gamage
✓	14 Gym Weight RM	Drinking Fountain, Refrigerated	✓ W01A-19 3033 (DF)	Thursday November 15, 2018 4:47	Dhanushka Gamage
✓	15 Hall @ Rm 201	Drinking Fountain, Refrigerated	✓ W01A-143033 (DF)	Thursday November 15, 2018 4:26	Dhanushka Gamage
✓	16 Hall Across RN 523	Drinking Fountain, Refrigerated	✓ W01A-12 3033 (DF) Left	Thursday November 15, 2018 4:11	Dhanushka Gamage
✓	17 Hall Across RN 523	Drinking Fountain, Refrigerated	✓ W01A-12 3033 (DF) Right	Thursday November 15, 2018 4:11	Dhanushka Gamage
✓	18 Health Room	Ice Machine	✓ K17-06 3033 (IM)	Thursday November 15, 2018 4:30	Dhanushka Gamage
✓	19 Health Room Main Office	Non-Kitchen lavatory/Sink	✓ S23-001 3033 (NO)	Thursday November 15, 2018 4:32	Dhanushka Gamage
✓	20 Kitchen	Ice Machine	✓ K17-01 3033 (IM)	Thursday November 15, 2018 3:28	Dhanushka Gamage

Samples Relinquished By: *D. Gamage*

Samples Received By: *[Signature]*

Temp: _____

✗ REMOVED

39 samples



Multiple Sample COC

Site: **Middletown High: 200 Schoolhouse Drive, Office Ph.: Middletown, MD 21769**

Date Sampled: **Thursday November 15, 2018**

Row	Area Number/Room/Space	From Item Description	Sample Name:	Date/Time Sampled (ex: 03/01/2018 13:28)	Sampler's Name
✓ 21	Kitchen @ Dishwasher	Sink, Kitchen	✓ K31-03 3033 (KS) Left	Thursday November 15, 2018 3:21	Dhanushka Gamage
✓ 22	Kitchen @ Dishwasher	Sink, Kitchen	✓ K31-03 3033 (KS) Right	Thursday November 15, 2018 3:22	Dhanushka Gamage
✓ 23	Kitchen In Corner	Sink, Kitchen	✓ K31-02 3033 (KS)	Thursday November 15, 2018 3:34	Dhanushka Gamage
✓ 24	Kitchen Prep Area	Sink, Kitchen	✓ K31-01 3033 (KS) Left	Thursday November 15, 2018 3:36	Dhanushka Gamage
✓ 25	Kitchen Prep Area	Sink, Kitchen	✓ K31-01 3033 (KS) Right	Thursday November 15, 2018 3:37	Dhanushka Gamage
✓ 26	Main Hall @ RM 431	Drinking Fountain, Refrigerated	✓ W01A-09 3033 (DF)	Thursday November 15, 2018 3:57	Dhanushka Gamage
* 27	Main Hall @ RM 433	Drinking Fountain, Refrigerated	W01A-08 3033 (DF) REMOVED	Thursday November 15, 2018	Dhanushka Gamage
✓ 28	Main Hall-Principal	Drinking Fountain, Refrigerated	✓ W01A-02 3033 (DF)	Thursday November 15, 2018 4:35	Dhanushka Gamage
* 29	Main Office/Guidance	Drinking Fountain, Refrigerated	W01A-01 3033 (DF) REMOVED	Thursday November 15, 2018	Dhanushka Gamage
✓ 30	Maint Office Counter	✓ Non-Kitchen lavatory/Sink	✓ S23-031 3033 (OT)	Thursday November 15, 2018 4:08	Dhanushka Gamage
✓ 31	Pool @ Coach Office	Drinking Fountain, Non-Refrigerated	✓ W01B-01 3033 (DF)	Thursday November 15, 2018 4:59	Dhanushka Gamage
✓ 32	Pool @ Girls Locker RM	Drinking Fountain, Non-Refrigerated	✓ W01B-02 3033 (DF)	Thursday November 15, 2018 4:57	Dhanushka Gamage
✓ 33	RM 411 Staff Lounge	Non-Kitchen lavatory/Sink	✓ S23-201 3033 (TL)	Thursday November 15, 2018 3:41	Dhanushka Gamage
✓ 34	RM 420A	Drinking Fountain, Refrigerated	✓ W01A-10 3033 (DF)	Thursday November 15, 2018 3:53	Dhanushka Gamage
✓ 35	RM 420A Early Childhood Dev. Kitch	Non-Kitchen lavatory/Sink	✓ S23-195 3033 (HE)	Thursday November 15, 2018 3:51	Dhanushka Gamage
✓ 36	RM 422A Small Kitchen	Non-Kitchen lavatory/Sink	✓ S23-202 3033 (HE)	Thursday November 15, 2018 3:49	Dhanushka Gamage
✓ 37	RM 430	Non-Kitchen lavatory/Sink	✓ S23-190 3033 (HE)	Thursday November 15, 2018 4:00	Dhanushka Gamage
✓ 38	Science Room 307 Prep	Ice Machine	✓ K17-04 3033 (IM)	Thursday November 15, 2018 4:22	Dhanushka Gamage
✓ 39	Gym - ME22 - CONC STAIRS SINK		- S23-207 3033 (OT) LEFT	4 4 4 4:44	n
✓ 40	Gym - ME22 - CONC STAIRS SINK		- S23-207 3033 (OT) RIGHT	4 4 4 4:45	u

* REMOVED

Samples Relinquished By: _____

Samples Received By: _____

Temp: _____

Jon Or III 11/15/18 4:40

39 samples