



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Tidewater

Project Name: Walkersville High

Meneka Rodrigo
6625 Selnick Drive, Suite A
Elkridge, MD 21075

Project / PO Number: N/A
Received: 01/15/2019
Reported: 01/25/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (K31-01 3054 KS, Drinking Water, 19A0861-01, etc.)

Table header for Metals, Total by EPA 200 Series Methods with columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row for Lead with values: 32.4, 20.0, 1.0, ppb, 01/22/19 1717, 01/24/19 1652, GHW

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (K31-02 3054 KS, Drinking Water, 19A0861-02, etc.)

Table header for Metals, Total by EPA 200 Series Methods with columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row for Lead with values: 11.2, 20.0, 1.0, ppb, 01/22/19 1717, 01/24/19 1656, GHW

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (K31-03 3054 KS, Drinking Water, 19A0861-03, etc.)

Table header for Metals, Total by EPA 200 Series Methods with columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row for Lead with values: 9.8, 20.0, 1.0, ppb, 01/22/19 1717, 01/24/19 1657, GHW

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (K31-04 3054 KS, Drinking Water, 19A0861-04, etc.)

Table header for Metals, Total by EPA 200 Series Methods with columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row for Lead with values: 17.1, 20.0, 1.0, ppb, 01/22/19 1717, 01/24/19 1659, GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: K31- 05 3054 KS (Left)	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:26
Lab Sample ID: 19A0861-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.6	20.0	1.0	ppb		01/22/19 1717	01/24/19 1703	GHW

Client Sample ID: S23-177 3054 TL	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:36
Lab Sample ID: 19A0861-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.3	20.0	1.0	ppb		01/22/19 1717	01/24/19 1704	GHW

Client Sample ID: S23-138 3054 TL	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:36
Lab Sample ID: 19A0861-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		01/22/19 1717	01/24/19 1705	GHW

Client Sample ID: S23-179 3054 NO	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:27
Lab Sample ID: 19A0861-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		01/22/19 1717	01/24/19 1707	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: S23-33 3054 HE	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:15
Lab Sample ID: 19A0861-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.2	20.0	1.0	ppb		01/22/19 1717	01/24/19 1708	GHW

Client Sample ID: S23-34 3054 HE	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:16
Lab Sample ID: 19A0861-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	44.2	20.0	1.0	ppb		01/22/19 1717	01/24/19 1709	GHW

Client Sample ID: S23- 35 3054 HE	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:17
Lab Sample ID: 19A0861-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	49.4	20.0	1.0	ppb		01/22/19 1717	01/24/19 1711	GHW

Client Sample ID: S23-36 3054 HE	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:20
Lab Sample ID: 19A0861-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	14.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1715	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: OT-01 3054 OT	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:05
Lab Sample ID: 19A0861-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		01/22/19 1717	01/24/19 1719	GHW

Client Sample ID: K17- 01 3054 IM	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:33
Lab Sample ID: 19A0861-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1720	GHW

Client Sample ID: K17- 02 3054 IM	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:29
Lab Sample ID: 19A0861-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.5	20.0	1.0	ppb		01/22/19 1717	01/24/19 1721	GHW

Client Sample ID: K17- 03 3054 IM	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:41
Lab Sample ID: 19A0861-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1723	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: K17- 04 3054 IM	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:44
Lab Sample ID: 19A0861-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1724	GHW

Client Sample ID: K17- 06 3054 IM	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:33
Lab Sample ID: 19A0861-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1725	GHW

Client Sample ID: K17- 07 3054 IM	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:42
Lab Sample ID: 19A0861-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1727	GHW

Client Sample ID: W01A-01 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:46
Lab Sample ID: 19A0861-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	10.8	20.0	1.0	ppb		01/22/19 1717	01/24/19 1728	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: W01A-02 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:40
Lab Sample ID: 19A0861-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.6	20.0	1.0	ppb		01/22/19 1717	01/24/19 1735	GHW

Client Sample ID: W01A-03 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:00
Lab Sample ID: 19A0861-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1739	GHW

Client Sample ID: W01A-04 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:01
Lab Sample ID: 19A0861-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		01/22/19 1717	01/24/19 1740	GHW

Client Sample ID: W01A-05 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:17
Lab Sample ID: 19A0861-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1742	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: W01A-06 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:18
Lab Sample ID: 19A0861-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1743	GHW

Client Sample ID: W01A-07 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:21
Lab Sample ID: 19A0861-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		01/22/19 1717	01/24/19 1744	GHW

Client Sample ID: W01A-08 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:22
Lab Sample ID: 19A0861-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		01/22/19 1717	01/24/19 1746	GHW

Client Sample ID: W01A-09 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:27
Lab Sample ID: 19A0861-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1747	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: W01A-10 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:49
Lab Sample ID: 19A0861-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.8	20.0	1.0	ppb		01/22/19 1717	01/24/19 1751	GHW

Client Sample ID: W01A-11 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:50
Lab Sample ID: 19A0861-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.2	20.0	1.0	ppb		01/22/19 1717	01/24/19 1752	GHW

Client Sample ID: W01A-12 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:54
Lab Sample ID: 19A0861-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1754	GHW

Client Sample ID: W01A-13 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:56
Lab Sample ID: 19A0861-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1758	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: W01A- 14 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:02
Lab Sample ID: 19A0861-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.3	20.0	1.0	ppb		01/22/19 1717	01/24/19 1759	GHW

Client Sample ID: W01A-15 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:06
Lab Sample ID: 19A0861-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.8	20.0	1.0	ppb		01/22/19 1717	01/24/19 1800	GHW

Client Sample ID: W01A-16 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:00
Lab Sample ID: 19A0861-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		01/22/19 1717	01/24/19 1802	GHW

Client Sample ID: W01A-17 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:23
Lab Sample ID: 19A0861-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.5	20.0	1.0	ppb		01/22/19 1717	01/24/19 1803	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: W01A-18 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:14
Lab Sample ID: 19A0861-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.6	20.0	1.0	ppb		01/22/19 1717	01/24/19 1807	GHW

Client Sample ID: W01A-19 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:10
Lab Sample ID: 19A0861-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.3	20.0	1.0	ppb		01/22/19 1717	01/24/19 1808	GHW

Client Sample ID: W01A-20 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:20
Lab Sample ID: 19A0861-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/22/19 1717	01/24/19 1810	GHW

Client Sample ID: W01B-01 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:15
Lab Sample ID: 19A0861-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		01/22/19 1717	01/24/19 1811	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Client Sample ID: W01B-02 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:13
Lab Sample ID: 19A0861-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.8	20.0	1.0	ppb		01/22/19 1717	01/24/19 1815	GHW

Client Sample ID: W01B-04 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 4:53
Lab Sample ID: 19A0861-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.8	20.0	1.0	ppb		01/22/19 1717	01/24/19 1819	GHW

Client Sample ID: W01B-05 3054 DF	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 5:10
Lab Sample ID: 19A0861-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	9.6	20.0	1.0	ppb		01/22/19 1717	01/24/19 1823	GHW

Client Sample ID: K-31-06-3054- KS	Collected By: Dhanushka Gamage
Sample Matrix: Drinking Water	Collection Date: 01/12/2019 3:26
Lab Sample ID: 19A0861-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	25.9	20.0	1.0	ppb		01/22/19 1717	01/24/19 1825	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 3.0°C



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19A0861

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	Yes
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	Yes
VOA vials have zero headspace, or not recd.?	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. - Baltimore
109

State of Maryland (Drinking Water)

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Megan Greenfield
Customer Relationship Coordinator
Reported: 01/25/2019 10:40



19A0861



Multiple Sample COC

Site: **Walkersville High: 81 West Frederick Street, Office Ph.: Walkersville, MD 21793**Date Sampled: **Saturday, January 12, 2019**

Row	Area Number/Room/Space	From Item Description	Sample Name:	Date/Time Sampled (ex: 03/01/2018 13:28)	Sampler's Name
1	KITCHEN @ 133/134	Sink, Kitchen	K31-01 3054 KS 3-22 AM	Saturday, January 12, 2019	Dhanushka Gamage
2	KITCHEN @ 133/134	Sink, Kitchen	K31-02 3054 KS 3-23	Saturday, January 12, 2019	Dhanushka Gamage
3	KITCHEN @ 133/134	Sink, Kitchen	K31-03 3054 KS 3-24	Saturday, January 12, 2019	Dhanushka Gamage
4	KITCHEN @ 133/134	Sink, Kitchen	K31-04 3054 KS 3-25	Saturday, January 12, 2019	Dhanushka Gamage
5	KITCHEN @ 133/134	Sink, Kitchen	K31-05 3054 KS (LEFT) 3-26	Saturday, January 12, 2019	Dhanushka Gamage
6	TEACHERS LOUNGE @ 104	Non-Kitchen lavatory/Sink	S23-177 3054 TL (RIGHT) 4-36	Saturday, January 12, 2019	Dhanushka Gamage
7	TEACHERS LOUNGE @ 142	Non-Kitchen lavatory/Sink	S23-138 3054 TL 3-36	Saturday, January 12, 2019	Dhanushka Gamage
8	NURSES OFFICE @ 110	Non-Kitchen lavatory/Sink	S23-179 3054 NO 4-27	Saturday, January 12, 2019	Dhanushka Gamage
9	HOME EC. @ 177	Non-Kitchen lavatory/Sink	S23-33 3054 HE 4-15	Saturday, January 12, 2019	Dhanushka Gamage
10	HOME EC. @ 179	Non-Kitchen lavatory/Sink	S23-34 3054 HE 4-16	Saturday, January 12, 2019	Dhanushka Gamage
11	HOME EC. @ 179	Non-Kitchen lavatory/Sink	S23-35 3054 HE 4-17	Saturday, January 12, 2019	Dhanushka Gamage
12	HOME EC. @ 176	Non-Kitchen lavatory/Sink	S23-36 3054 HE 4-20	Saturday, January 12, 2019	Dhanushka Gamage
13	COOLER ROOM @ COOLER ROOM	Non-Kitchen lavatory/Sink	OT-01 3054 OT 5-05	Saturday, January 12, 2019	Dhanushka Gamage
14	FRONT OFFICE FACULTY LOUNGE	Ice Machine	K17-01 3054 IM 4-33	Saturday, January 12, 2019	Dhanushka Gamage
15	NURSES OFFICE @ 110	Ice Machine	K17-02 3054 IM 4-29	Saturday, January 12, 2019	Dhanushka Gamage
16	ATHLETIC LAUNDRY ROOM @ 116	Ice Machine	K17-03 3054 IM 4-41	Saturday, January 12, 2019	Dhanushka Gamage
17	COOLER ROOM @ COOLER ROOM	Ice Machine	K17-04 3054 IM 4-44	Saturday, January 12, 2019	Dhanushka Gamage
* 18	BUILDING SERVICES @ BUILDING	Ice Machine (NOT IN SERVICE)	K17-05 3054 IM -	Saturday, January 12, 2019	Dhanushka Gamage
19	KITCHEN @ 133	Ice Machine	K17-06 3054 IM 5-33	Saturday, January 12, 2019	Dhanushka Gamage
20	SCIENCE PREP @ 148	Ice Machine	K17-07 3054 IM 3-42 AM	Saturday, January 12, 2019	Dhanushka Gamage
Samples Relinquished By:				LOUIS @ 1/15/19	
Samples Received By:					
Temp:					



Multiple Sample COC

Site: **Walkersville High: 81 West Frederick Street, Office Ph.: Walkersville, MD 21793**

Date Sampled: **Saturday, January 12, 2019**

Row	Area Number/Room/Space	From Item Description	Sample Name:	Date/Time Sampled (ex: 03/01/2018 13:28)	Sampler's Name
21	MENS LOCKERROOM @ MENS LOC	Drinking Fountain	W01A-01 3054 DF	4:46 AM Saturday, January 12, 2019	Dhanushka Gamage
22	WOMENS LOCKERROOM @ WOME	Drinking Fountain	W01A-02 3054 DF	4:40 Saturday, January 12, 2019	Dhanushka Gamage
23	BY ATHLETIC DIRECTORS OFFICE	Drinking Fountain	W01A-03 3054 DF	5:00 Saturday, January 12, 2019	Dhanushka Gamage
24	BY ATHLETIC DIRECTORS OFFICE	Drinking Fountain	W01A-04 3054 DF	5:01 Saturday, January 12, 2019	Dhanushka Gamage
25	CAFETERIA @ 132	Drinking Fountain	W01A-05 3054 DF	3:17 Saturday, January 12, 2019	Dhanushka Gamage
26	CAFETERIA @ 132	Drinking Fountain	W01A-06 3054 DF	3:18 Saturday, January 12, 2019	Dhanushka Gamage
27	HALL BY WRESTLING ROOM @ 120	Drinking Fountain	W01A-07 3054 DF	5:21 Saturday, January 12, 2019	Dhanushka Gamage
28	HALL BY WRESTLING ROOM @ 120	Drinking Fountain	W01A-08 3054 DF	5:22 Saturday, January 12, 2019	Dhanushka Gamage
29	AG SHOP @ 121	Drinking Fountain	W01A-09 3054 DF	5:27 Saturday, January 12, 2019	Dhanushka Gamage
30	BY SCIENCE PREP @ HALL BY RO	Drinking Fountain	W01A-10 3054 DF	3:49 Saturday, January 12, 2019	Dhanushka Gamage
31	BY SCIENCE PREP @ HALL BY RO	Drinking Fountain	W01A-11 3054 DF	3:50 Saturday, January 12, 2019	Dhanushka Gamage
32	MATH HALLWAY @ HALL BY ROOM	Drinking Fountain	W01A-12 3054 DF	3:54 Saturday, January 12, 2019	Dhanushka Gamage
33	MATH HALLWAY @ HALL BY ROOM	Drinking Fountain	W01A-13 3054 DF	3:56 Saturday, January 12, 2019	Dhanushka Gamage
34	IN ROOM 160 @ 160	Drinking Fountain	W01A-14 3054 DF	4:02 Saturday, January 12, 2019	Dhanushka Gamage
35	IN ROOM 164 @ 164	Drinking Fountain	W01A-15 3054 DF	4:06 Saturday, January 12, 2019	Dhanushka Gamage
36	HALL BY AUDITORIUM @ HALL BY	Drinking Fountain	W01A-16 3054 DF	4:00 Saturday, January 12, 2019	Dhanushka Gamage
37	HALL BY FACULTY R.R. @ HALL BY	Drinking Fountain	W01A-17 3054 DF	4:23 Saturday, January 12, 2019	Dhanushka Gamage
38	IN ROOM 177 @ IN ROOM 177	Drinking Fountain	W01A-18 3054 DF	4:14 Saturday, January 12, 2019	Dhanushka Gamage
39	OUTSIDE MUSIC ROOM @ HALL BY	Drinking Fountain	W01A-19 3054 DF	4:10 Saturday, January 12, 2019	Dhanushka Gamage
40	WEIGHT ROOM @ WEIGHT ROOM	Drinking Fountain	W01A-20 3054 DF	5:20 AM Saturday, January 12, 2019	Dhanushka Gamage
Samples Relinquished By: <i>[Signature]</i>					
Samples Received By: <i>[Signature]</i>				1/15/19	<i>[Signature]</i>
Temp:					

