



South Jersey

Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

856-875-3506 Phone

856-875-3507 Fax

www.sjwatertest.com

NJ DEP Certified Lab #08006

Friday, January 06, 2017

Bob Forrester

Atlantic Community Charter School

112 South New York Road

Galloway, NJ 08302

Certificate of Analysis

Sample Location: ACS01

Date/Time Sampled: 12/17/2016 08:15

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59449					
Lead	12/21/2016 10:40	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:03	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS02

Date/Time Sampled: 12/17/2016 08:16

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59450					
Lead	12/21/2016 10:46	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:04	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS03

Date/Time Sampled: 12/17/2016 08:20

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59451					
Lead	12/21/2016 11:03	3.10	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:04	<0.05	1.3	mg/L	0.05	SM3111B



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Sample Location: ACS04

Date/Time Sampled: 12/17/2016 08:22

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59452					
Lead	12/21/2016 11:09	5.33	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:05	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS05

Date/Time Sampled: 12/17/2016 08:23

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59453					
Lead	12/21/2016 11:14	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:05	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS06

Date/Time Sampled: 12/17/2016 08:25

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59454					
Lead	12/21/2016 11:25	5.78	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:06	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS07

Date/Time Sampled: 12/17/2016 08:31

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59455					
Lead	12/21/2016 11:30	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:07	<0.05	1.3	mg/L	0.05	SM3111B



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Sample Location: ACS08

Date/Time Sampled: 12/17/2016 08:30

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59456					
Lead	12/21/2016 11:36	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:07	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS09

Date/Time Sampled: 12/17/2016 08:21


Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59457					
Lead	12/21/2016 11:42	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:08	<0.05	1.3	mg/L	0.05	SM3111B

Sample Location: ACS10

Date/Time Sampled: 12/17/2016 08:35

Test/ Parameter	Date/Time Analyzed	Result	Allowable Limit	Units	Reporting Limit	Method
Sample ID	O59458					
Lead	12/21/2016 11:47	<2.0	15	ug/L	2.0	SM3113B
Copper	12/22/2016 14:08	<0.05	1.3	mg/L	0.05	SM3111B

This report relates only to the samples as received by the laboratory.



Mark J. Riether, Lab Director

11/6/17

Date